AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Western Window Systems
2200 E. Riverview Drive
Phoenix, AZ 85034

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

<table>
<tr><td colspan="2">SPECIFICATIONS</td><td colspan="3" rowspan="2">RECORD OF PRODUCT TESTED</td></tr>
<tr><td>AAMA/WDMA/CSA 101/I.S.2/A440-22
CW-PG55 4572x3048 (180x120)-FW
and AAMA 450
Negative Design Pressure = -60 psf</td><td>AAMA 506</td></tr>
<tr><td>COMPANY AND PLANT LOCATION</td><td rowspan="2">Missile Level: D
Wind Zone 3
Rating: 60
MST: 180 x 120

Rating above conforms to requirements of:
ASTM E 1886 and
ASTM E 1996</td><td>CPD NO.</td><td>SERIES MODEL
& PRODUCT DESCRIPTION</td><td>MAXIMUM SIZE TESTED</td></tr>
<tr><td>Western Window Systems
Code: WWD</td><td>23293</td><td>7630 PICTURE WINDOW FIN
(AL) (OOO) (OG) (ASTM)
(INS TEMP / SG LAM H.S. GL)</td><td><u>FRAME (mm)</u>
4572 x 3048
(180” x 120”)</td></tr>
<tr><td colspan="2">Design Pressure
(psf): +60/-60 (Pa): +2873/-2873</td><td colspan="3">Water Test Pressure
(psf): 9.0 (Pa): 431</td></tr>
</table>

1. This Certification will expire **June 14, 2029,** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Product Tested and Reported by:

QAI Laboratories

Report No.: **MED-0043aR2, 8/13/2026 QAI Letter**

Date of Report: **Nov. 21, 2024 (Rev.2 Aug. 13, 2026)**

Date Test Completed: **June 14, 2024**

Missile Impact Test & Report by:

QAI Laboratories

Report No.: **MED-0043aR2, 8/13/2026 QAI Letter**

Date of Report: **Nov. 21, 2024 (Rev.2 Aug. 13, 2026)**

Date Test Completed: **June 14, 2024**

A·L·I

(Validator / Operations Administrator)

Evaluated for Certification: **September 9, 2026**

Associated Laboratories, Inc.

ALL CERTIFIED PRODUCTS MUST BE PRODUCED WITH TEMPERED GLASS AND LAMINATED HEAT-STRENGTHENED GLASS.

Authorized for Certification: **September 9, 2026**

Fenestration and Glazing Industry Alliance