AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Western Window Systems
2200 E. Riverview Drive
Phoenix, AZ 85034

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of tests by an AAMA Accredited Laboratory. The listing below will be added to the next update to the AAMA Certified Products Directory.

<table>
<tr><td colspan="2">SPECIFICATIONS</td><td colspan="4" rowspan="2">RECORD OF PRODUCT TESTED</td></tr>
<tr><td>AAMA/WDMA/CSA 101/I.S.2/A440-22
LC-PG45 3353x3048 (132x120)-SD
Negative Design Pressure = -50 psf</td><td>AAMA 506</td></tr>
<tr><td>COMPANY AND PLANT LOCATION</td><td rowspan="2">Missile Level: D
Wind Zone 3
Rating: 50
MST: 132 x 120

Rating above conforms to requirements of:
ASTM E 1886 and ASTM E 1996</td><td>CPD NO.</td><td>SERIES MODEL & PRODUCT DESCRIPTION</td><td colspan="2">MAXIMUM SIZE TESTED</td></tr>
<tr><td>Western Window Systems
Code: WWD</td><td>23283</td><td>SGD7600 SLIDING DOOR w/TWO PANELS 90°-FINLESS
(AL) (OX-XXop) (OG)
(ASTM)
(INS SG LAM H.S. GL)</td><td><u>FRAME (mm)</u>
3353 x 3048
(132” x 120”)</td><td><u>PANEL (mm)</u>
1483 x 3010
(58” x 119”)

<u>90° PANELS (mm)</u>
1503 x 3010
(59” x 119”)</td></tr>
<tr><td colspan="3">Design Pressure
(psf): +50/-50 (Pa): +2394/-2394</td><td colspan="3">Water Test Pressure
(psf): 7.5 (Pa): 359</td></tr>
</table>

1. This Certification will expire **April 15, 2029,** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

2. Product Tested and Reported by:

QAI Laboratories

Report No.: **MED-0051b, 8/13/2026 QAI Letter**

Date of Report: **April 18, 2024 (Rev. August 4, 2026)**

Date Test Completed: **April 15, 2024**

Missile Impact Test & Report by:

QAI Laboratories

Report No.: **MED-0051b, 8/13/2026 QAI Letter**

Date of Report: **April 18, 2024 (Rev. August 4, 2026)**

Date Test Completed: **April 15, 2024**

A·L·I

(Validator / Operations Administrator)

Evaluated for Certification: **September 9, 2026**

Associated Laboratories, Inc.

Authorized for Certification: **September 9, 2026**

Fenestration and Glazing Industry Alliance